



Urgent Facilities Information

Risk Alert

August 2015

www.npip.org

Have questions?
If you have any questions regarding this risk alert, please contact your local agent, or your Clear Risk Solutions Risk Manager directly at 800.407.2027.

In response to the challenges presented by the current fires, NPIP would like to suggest information and recommendations for our entities in the fire areas and areas affected by poor air quality from the fires.



1. Make every effort to keep your building sealed by closing fresh air intakes and making sure doors close and seal properly. This reduces the exposure of internal systems to smoke and particulate damage.
2. Keep your HVAC fans running to allow the system filters to assist in keeping particulate exposure to a minimum. Be mindful that this approach will necessitate increased maintenance of system filters to keep them as effective as possible.
3. When safe to do so, carefully inspect your roof for damage from embers which may have landed on your facilities. Damage does not necessarily have to be large to create pathways for water when fall and winter weather arrives. To reduce the likelihood of water damage, fix damage as soon as possible.

If you have any questions regarding this information, please contact your local agent or Clear Risk Solutions Risk Manager.